

# INDICATING BUTTERFLY VALVE

**PRATT®**

(Underwriters Laboratory Listed and FM Approved)

1. Butterfly valves for above ground use shall be of the indicating type with a highly visible yellow flag on the valve actuator which indicates whether the valve is open or closed.
2. The valve actuator shall be a traveling nut type and have an input rating of 450 ft. lbs. of torque against the input stops.
3. Externally, the actuator shall be driven by a crank or 2" nut which is affixed to the input shaft by a shear pin.
4. Butterfly valves shall be Pratt Indicating Butterfly Valves Underwriters Laboratory listed and Factory Mutual approved as manufactured by the Henry Pratt Company.
5. Valves shall be manufactured in accordance with AWWA C504-94, Class 150B.



Henry Pratt Company 1.630.844.4000  
www.henrypratt.com  
moreinfo@henrypratt.com

Mueller Canada) 1.905.878.0541  
www.muellercanada.com  
more-info@muellercanada.com

International 1.423.490.9555  
www.mueller-international.com  
international@muellercompany.com

Copyright © 2016 Henry Pratt Company, LLC. All Rights Reserved. The trademarks, logos and service marks displayed in this document herein are the property of Henry Pratt Company, its affiliates or other third parties.